

FAX-MEMO

QUANTUM Environmental

2100035

Engineering and Geologic Consulting

South 2195 Silver Beach Loop * Cour d'Alene, Idaho 83814

208*765*2308

quantum@comtech,iaq.com

TO: Dave Birney

BUSINESS: Environmental Protection Agency

FAX: 509 353 2535

DATE: 5/13/99

FROM: Jim De Smet

TOTAL PAGES: 2 (Includes Cover Page)

COMMENTS: I was present for the removal of the tank. A PID was used to screen the excavated soils and the bottom of the excavation. All soil readings were below the detection limit of the instrument. As such, the excavated soil was returned to the excavation after sampling of the bottom of the excavation. The tank was cleaned, removed and disposed by the removal contractor for scrap.


I have also attached a copy of the site sketch.

Sincerely:



James S. De Smet, PE, PG

1" = 30'



Marina Bldg.

Concrete Pad 24'

28'

Tank I-S.
Tank I-N

Roadway